

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-0026:267 Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** Simplex, 100 Simplex Drive, Westminster, MA 01441-0001  
Contact: Paul Mattern (978) 731-854 \*Fax (978) 731-88812

**DESIGN:** Model SONITROL PLUS fire alarm control unit. Central station (protected premise service); automatic, manual, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

Base Module (90225102)	Main Board
Telplus Module	Telephone Interface
APS12V1A-S	Power Supply Module
ADV-LIM	Listen In Module
LCD, LCD Plus	Keypad
ADV-LEM	Loop Expansion Module
07916301/07916302/07916303	"Attack" Enclosure
07916201/07916202/07916203	"Standard" Enclosure
40003501	Transformer Enclosure
90255100	Telephone Block
90228102	Smart Audio Module

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** Burglary and other non-fire functions are not examined.

**NOTE:** Formerly 7165-1379:102

\*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 17, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager